



**Delhi Electricity Regulatory Commission**  
**Viniyamak Bhawan, 'C' Block, Shivalik, Malviya Nagar, New Delhi – 17**

No. F.11(1534)/DERC/2017-18

**Petition No. 56/2017**

**In the matter of:**      **Petition under Section 86 (1)(b) and other provisions of the Electricity Act, 2003 for approval of bidding process, adoption of tariff of Municipal Waste based plant and approval of draft PPA.**

South Delhi Municipal Corporation  
Dr. SPM Civic Centre, JLN Marg,  
New Delhi 110 002

...Petitioner

**VERSUS**

1. Tata Power Delhi Distribution Ltd.  
**Through its: Managing Director**  
33Kv Sub Station Building,  
Hudson Lane,  
Delhi 110 009.
2. BSES Rajdhani Power Limited  
**Through its : CEO**  
BSES Bhawan, Nehru Place,  
New Delhi-110019.
3. Chief Engineer (Utilities) CWE,  
MES, Kotwali Road, Delhi Cantt.  
New Delhi 110011
4. BSES Yamuna Power Ltd.  
**Through its: CEO**  
Shakti Kiran Building,  
Karkardooma  
New Delhi – 110 092.
5. The Secretary  
New Delhi Municipal Council  
Palika Kendra, Sansad Marg  
New Delhi 100 001
6. Delhi Transco Limited  
Shakti Sadan, Kotla Road,  
New Delhi 110002
7. State Load Despatch Centre  
Delhi Shakti Sadan, Kotla Road,  
New Delhi 110002

...Respondents

**Coram: Hon'ble Mr. Justice S S Chauhan, Chairperson  
Hon'ble Mr. B.P. Singh, Member**

**Appearance:**

1. Ms. Swapna Seshadri, Adv. SMDC
2. Mr. Ashwin Ramanathan, Adv. SDMC
3. Mr. Ankit Jain, Adv. NDMC
4. Mr. Mayank Garg, Adv.
5. Mr. Tushar, Adv. NDMC
6. Mr. Rahul Kinra, Adv. TPDDL
7. Mr. Buddy Ranganadhan, BRPL, BYPL
8. Ms. Malvika Prasad, Adv. BRPL & BYPL
9. Ms. Anoushka Singh, Adv. BRPL & BYPL
10. Mr. Jaspal Singh, Jindal
11. Mr. Neelesh Gupta, Jindal
12. Mr. Anurag Bansal, TPDDL
13. Mr. Bharat Bhadawat, TPDDL
14. Ms. Kanupriya Mehndiratta, TPDDL
15. Mr. Mithun Chakraborty, TPDDL
16. Mr. G.B.Swain, BYPL
17. Mr. Abhishek Srivastava, BYPL
18. Mr. Rajeev Chowdhary, BRPL
19. Mr. Kanishk, BRPL
20. Mr. Shashi Garg, BRPL
21. Mr. Shekhar Saklani, BYPL
22. Mr. Sunil Kakkar, BYPL
23. Mr. Pardeep, NDMC

**INTERIM ORDER**

(Date of Hearing: 04.09.2018)  
(Date of Order: 11.09.2018)

1. The Counsel appearing on behalf of the Petitioner submitted that various issues raised by the Respondent have been reconciled and accepted by the Petitioner. Further, it was argued that the pre-conditions of 72 hours of continuous running of plant prior to its commissioning is not practically feasible for MSW Plants and therefore may not be made applicable in the instant case.
2. Notwithstanding the Petitioner is directed to file a copy of the certificate complying the norms of emission within three days.
3. List the matter for hearing on 11.09.2018 at 3:00pm.

**Sd/-  
(B.P. Singh)  
Member**

**Sd/-  
(Justice S S Chauhan)  
Chairperson**