

DELHI ELECTRICITY REGULATORY COMMISSION

Viniyamak Bhavan, C-Block, Shivalik, Malviya Nagar, New Delhi -110017

F.3(452)Tariff-Engg./DERC/2016-17/5302

Date: 19.09.2017

CORRIGENDUM

Reference DERC Tariff Order for Indraprastha Power Generation Company Limited (IPGCL) for FY 2017-18 dated 31.08.2017

In this connection, it is stated that Gross Station Heat Rate (GHR) for Gas Turbine Power Station (GTPS) indicated in Para 4.27 shall be read as specified in Regulation 8(2) of the DERC Business Plan Regulations, 2017, which is as follows:

“2450 kCal/ kWh and 3125 kCal/ kWh for Combined Cycle and Open Cycle mode operation respectively”

instead of

“2100 kCal/ kWh and 3045 kCal/ kWh for Combined Cycle and Open Cycle mode operation respectively”

IPGCL shall raise the invoice based on GHR of 2450 kCal/ kWh and 3125 kCal/ kWh for Combined Cycle and Open Cycle mode operation respectively to the beneficiaries.

This Corrigendum is also available on DERC Website www.derc.gov.in.

Sd/-

Secretary

DELHI ELECTRICITY REGULATORY COMMISSION